

StormSlim Tank Retention Height Look-up Table

1,000L StormSlim Tank	
Required Retention Volume (L)	Orifice IL from base of Tank (mm)
300	515
350	600
400	685
450	770
500	850
550	935
600	1020
650	1105
700	1190
750	1270
800	1355
850	1440
900	1525

2,000L StormSlim Tank	
Required Retention Volume (L)	Orifice IL from base of Tank (mm)
600	515
700	600
800	685
900	770
1000	850
1100	935
1200	1020
1300	1105
1400	1190
1500	1270
1600	1355
1700	1440
1800	1525

3,000L StormSlim Tank	
Required Retention Volume (L)	Orifice IL from base of Tank (mm)
900	515
1000	570
1100	630
1200	685
1300	740
1400	795
1500	850
1600	910
1700	965
1800	1020
1900	1075
2000	1130
2100	1190
2200	1245
2300	1300
2400	1355
2500	1410
2600	1470
2700	1525

5,000L StormSlim Tank	
Required Retention Volume (L)	Orifice IL from base of Tank (mm)
800	280
1000	350
1200	415
1400	480
1600	550
1800	615
2000	685
2200	750
2400	820
2600	885
2800	955
3000	1020
3200	1085
3400	1155
3600	1220
3800	1290
4000	1355
4200	1425
4400	1490

Notes:

Volumes in between those shown can be found by means of interpolation.

Alternatively, for volumes not shown please contact APD (09 263 7741).

