

STRUCTURAL CALCULATIONS

IN SLAB 300D TANK DESIGN IN RESIDENTIAL WAFFLE SLABS
TWO STOREY, CLASS M EXPANSIVITY SOILS

PROJECT

CLIENT

APD LTD

ADDRESS

APD LTD

DATE

1/05/2024

PROJECT NUMBER

7527-M(2)-220D

DOCUMENT CONTROL RECORD

Project	IN SLAB 300D TANK DESIGN IN RESIDENTIAL WAFFLE SLABS		
Client	APD LTD	Project Number	7527-M(2)-220D

Rev	Date	Revision Details	Author	Reviewed By	Approved By
A	1 May 2024	Building Consent	PS	AH	AH
Current Revision		A			

A person using DHC Consulting Group Ltd documents or data accepts the risk of:

- a) Using the documents or data in electronic form without requesting and checking them for accuracy against the original hard copy version.
- b) Using the documents or data for any purpose not agreed to in writing by DHC Consulting Group Ltd

Author

Approved By

Philip Seto

Alyx Hodgson

0211637818

Alyx@dhc.nz

philips@dhc.nz

Project:	IN SLAB 300D TANK DESIGN IN RESIDENTIAL WAFFLE SLABS	Project No:	7527-M(2)-220D
		Author:	Philip Seto
Subject:	Structural Calculations		

CONTENTS

1.	COUNCIL DOCUMENTATION	2
2.	FOUNDATIONS	3

Project:	IN SLAB 300D TANK DESIGN IN RESIDENTIAL WAFFLE SLABS	Project No:	7527-M(2)-220D
Subject:	Structural Calculations	Author:	Philip Seto

1. COUNCIL DOCUMENTATION

PRODUCER STATEMENT – PS1 DESIGN

BUILDING CODE CLAUSE(S): B1 | **JOB NUMBER:** 7527-M(2)-300D |
ISSUED BY: DHC Consulting Group Ltd |
(Engineering Design Firm)
TO: APD Ltd |
(Owner/Developer)
TO BE SUPPLIED TO: Building Consent Authority |
(Building Consent Authority)
IN RESPECT OF: Structural Design of concrete Waffle slabs for In slab tanks in class M soils - Two storey. |
(Description of Building Work)
AT: APD Ltd |
(Address, Town/City)
LEGAL DESCRIPTION: | **N/A** ☒

We have been engaged by the owner/developer referred to above to provide *(Extent of Engagement)*:
 Structural engineering design as per the calculations attached |
 in respect of the requirements of the Clause(s) of the Building Code specified above for Part only , as specified in the
 Schedule, of the proposed building work.

The design carried out by us has been prepared in accordance with:

- ☒ Compliance documents issued by the Ministry of Business, Innovation & Employment *(Verification method/acceptable solution)* B1/VM1, B1/VM4 | and/or;
- ☒ Alternative solution as per the attached Schedule.

The proposed building work covered by this producer statement is described on the drawings specified in the Schedule, together with the specification, and other documents set out in the Schedule.

On behalf of the Engineering Design Firm, and subject to:

- Site verification of the following design assumptions: Soils to 300kPa UBC, expansivity class M, AS2870 :2011 |.
- All proprietary products meeting their performance specification requirements;

I believe on reasonable grounds that:

- the building, if constructed in accordance with the drawings, specifications, and other documents provided or listed in the Schedule, will comply with the relevant provisions of the Building Code and that;
- the persons who have undertaken the design have the necessary competency to do so.

I recommend the CM 2 level of **construction monitoring**.

I, *(Name of Engineering Design Professional)* Alyx Hodgson , am:

- ☒ CPEng number 1019377 |
and hold the following qualifications BE(Hons), CMEngNZ, CPEng

The Engineering Design Firm holds a current policy of Professional Indemnity Insurance no less than \$200,000
 The Engineering Design Firm is a member of ACE New Zealand.

SIGNED BY *(Name of Engineering Design Professional)*: Alyx Hodgson
(Signature below):



ON BEHALF OF *(Engineering Design Firm)*: DHC Consulting Group Ltd

Date: 08/08/2025

Note: This statement has been prepared solely for the Building Consent Authority named above and shall not be relied upon by any other person or entity. Any liability in relation to this statement accrues to the Engineering Design Firm only. As a condition of reliance on this statement, the Building Consent Authority accepts that the total maximum amount of liability of any kind arising from this statement and all other statements provided to the Building Consent Authority in relation to this building work, whether in tort or otherwise, is limited to the sum of \$200,000.

This form is to accompany **Form 2 of the Building (Forms) Regulations 2004** for the application of a Building Consent.

SCHEDULE to PS1

Please include an itemised list of all referenced documents, drawings, or other supporting materials in relation to this producer statement below:

DHC Drawings REF NO. 7527-M(2)-300D - SHEETS: S002, S301-3

DHC Calculations REF NO. 7527-M(2)-300D - DATED: 2024.05.01

Maximum design load assumptions to slab edges:

Roof loads G/Q: 0.45kpa/0.25kpa x 3.0m (LD) x 1 Roof level

Floor loads G/Q: 0.6kpa/1.5kpa x 2.5m (LD) x 1 Floor level

Brick veneer wall loads G/Q: 1.54kpa/0kpa x 2.7 x 2 (2 storeys)

Weather board wall loads G/Q: 0.4kpa/0kpa x 2.7 x 2 (2 Storeys)

MAX UDL AND POINT LOADS AT PERIMETER FOOTING

WALL: G = 8.3KN/M (BRICK VENEER)
G = 2.16KN/M (WEATHER BOARD)

FLOOR: G = 1.5KN/M
Q = 3.75KN/M

ROOF: G = 1.35KN/M
Q = 0.75KN/M

GARAGE & DRIVEWAY:
G_{SDL} = 0.25KPA
Q = 2.5KPA
Q_{PL} = 12KN

Soil expansivity class assumptions: Class M, Y_s ≤ 40mm

The attached PS1 is subject to:

1. This statement is based on generic design of the concrete waffle slab only, without specific knowledge of the location or intended use of the product at the site referred to. The Owner/Developer and Building Consent Authority must be satisfied the specified product and the corresponding Producer Statement and manufacturer's specifications are applicable to the situation in which the product is to be used,
2. Any ground at the site directly supporting the slab providing an allowable working bearing capacity of 100kPa minimum
3. Any structure supporting the balustrade to be in accordance with the Building Code Acceptable Solutions or subject to specific design,
4. The work covered by this statement being carried out in accordance with the manufacturer's installation specifications,
5. all reinforced concrete work being carried out in accordance with NZS 3109 and NZS 3114, and
6. all structural steelwork work being carried out in accordance with NZS 3404, and
7. the engineering work covered by this statement being inspected at appropriate times during construction by the Building Consent Authority, geotechnical engineers % structural engineers as required by the building consent conditions

Referenced documents: Drawings Ref: 7527 – Dated 01/05/2024

Alternative Solutions: AS2870

Part only Schedule:

This PS1 covers part only of the building work for the following reason(s):

- This statement only covers the elements designed by DHC Consulting Group Ltd.

PS1 Expiry Date

This PS1 is valid for Building Consents lodged until the end of July 2026.

GUIDANCE ON USE OF PRODUCER STATEMENTS

Information on the use of Producer Statements and Construction Monitoring Guidelines can be found on the Engineering New Zealand website

<https://www.engineeringnz.org/engineer-tools/engineering-documents/producer-statements/>

Producer statements were first introduced with the Building Act 1991. The producer statements were developed by a combined task committee consisting of members of the New Zealand Institute of Architects (NZIA), Institution of Professional Engineers New Zealand (now Engineering New Zealand), Association of Consulting and Engineering New Zealand (ACE NZ) in consultation with the Building Officials Institute of New Zealand (BOINZ). The original suite of producer statements has been revised at the date of this form to ensure standard use within the industry.

The producer statement system is intended to provide Building Consent Authorities (BCAs) with part of the reasonable grounds necessary for the issue of a Building Consent or a Code Compliance Certificate, without necessarily having to duplicate review of design or construction monitoring undertaken by others.

PS1 DESIGN Intended for use by a suitably qualified independent engineering design professional in circumstances where the BCA accepts a producer statement for establishing reasonable grounds to issue a Building Consent;

PS2 DESIGN REVIEW Intended for use by a suitably qualified independent engineering design review professional where the BCA accepts an independent design professional's review as the basis for establishing reasonable grounds to issue a Building Consent;

PS3 CONSTRUCTION Forms commonly used as a certificate of completion of building work are Schedule 6 of NZS 3910:2013 or Schedules E1/E2 of NZIA's SCC 2011²

PS4 CONSTRUCTION REVIEW Intended for use by a suitably qualified independent engineering construction monitoring professional who either undertakes or supervises construction monitoring of the building works where the BCA requests a producer statement prior to issuing a Code Compliance Certificate.

This must be accompanied by a statement of completion of building work (Schedule 6).

The following guidelines are provided by ACE New Zealand and Engineering New Zealand to interpret the Producer Statement.

Competence of Engineering Professional

This statement is made by an engineering firm that has undertaken a contract of services for the services named, and is signed by a person authorised by that firm to verify the processes within the firm and competence of its personnel.

The person signing the Producer Statement on behalf of the engineering firm will have a professional qualification and proven current competence through registration on a national competence-based register such as a Chartered Professional Engineer (CPEng).

Membership of a professional body, such as Engineering New Zealand provides additional assurance of the designer's standing within the profession. If the engineering firm is a member of ACE New Zealand, this provides additional assurance about the standing of the firm.

Persons or firms meeting these criteria satisfy the term "suitably qualified independent engineering professional".

Professional Indemnity Insurance

As part of membership requirements, ACE New Zealand requires all member firms to hold Professional Indemnity Insurance to a minimum level.

The PI Insurance minimum stated on the front of this form reflects standard practice for the relationship between the BCA and the engineering firm.

Professional Services during Construction Phase

There are several levels of service that an engineering firm may provide during the construction phase of a project (CM1-CM5 for engineers³). The building Consent Authority is encouraged to require that the service to be provided by the engineering firm is appropriate for the project concerned.

Requirement to provide Producer Statement PS4

Building Consent Authorities should ensure that the applicant is aware of any requirement for producer statements for the construction phase of building work at the time the building consent is issued as no design professional should be expected to provide a producer statement unless such a requirement forms part of the Design Firm's engagement.

Refer Also:

- ¹ Conditions of Contract for Building & Civil Engineering Construction NZS 3910: 2013
- ² NZIA Standard Conditions of Contract SCC 2011
- ³ Guideline on the Briefing & Engagement for Consulting Engineering Services (ACE New Zealand/Engineering New Zealand 2004)
- ⁴ PN01 Guidelines on Producer Statements

www.acenz.org.nz
www.engineeringnz.org

To the Building Official,

Building Consent Authority

APD Ltd

Compliance with Building Code Clause B2 – Durability

The purpose of this letter is to demonstrate how compliance with Clause B2 (Durability) of the Building Code will be achieved for the above project. We can confirm that for specifically designed structural elements that are included within our design documentation:

Material	Means of compliance	Details
Reinforced concrete	B2/AS1	Concrete cover to reinforcing has been selected in accordance with NZS3101, Part 1, Section 3
Structural timber	B2/AS1	Timber treatment has been selected in accordance with Table 1A of B2/AS1
Mild steel structure	Alternative Solution	Protection for mild steel has been specified in accordance with SNZ TS 3404 – Durability requirements for steel structures and components and AS/NZS2312 – Guide to the protection of structural steel against atmospheric corrosion by the use of protective coatings. This guide works on a time to first maintenance basis and assumes on-going maintenance. Refer to the attached maintenance plan (optional but recommended).
Other		

Yours faithfully,

Alyx Hodgson

For and on behalf of

DHC Consulting Group Ltd

Structural maintenance schedule

This schedule of ongoing inspection and maintenance of structural elements shall be included with the Operations and Maintenance manuals and provided to the Owner/Body Corporate and building managers.

Inspection/maintenance timeframe and item	
Half-yearly	Wash down all exposed steelwork that is not in a fully interior environment including: • Veranda steelwork • Steel Carpark structure (beams, columns, braces etc) • Deck and balcony steelwork • Exposed façade steelwork, both primary and secondary structure • Plantrooms and plenums with fresh-air intakes • External structural components such as Buckling Restrained Braces, Viscous Dampers, Eccentrically Braced Frames and the like • Sub-ground floor mild-steel structures such as beams, isolation bearings etc.
(b) 5 yearly	Inspect and repair sealant that encloses structural mild-steel components and/or timber with mild-steel fixings
(c) 10 yearly	Check exposed timber fixings for corrosion, repair as required.
	Inspect/replace sealant that encloses structural mild-steel components and/or timber with mild-steel fixings. This will typically include sealants around the perimeter of precast panels. Note that 10 years is the expected useful life for many sealants
	Check exposed structural steel within plantrooms and plenums for corrosion. Repair protective coatings as required.
	Check all exposed steelwork that is not in a fully interior environment for signs of corrosion. Repair protective coatings as required.
	Audit of damage to exposed intumescent coatings. Repair as required.
(d) 25 yearly	Inspect samples of structural steel that is hidden from view but not enclosed within a vapour barrier, and repair protective coatings as necessary. A typical example is a veranda with built-in steelwork. (Such steelwork should typically have duplex protective coatings). Inspection may typically require removal of claddings and/or the drilling of holes for borescope access. Repair as required.
	Inspect all exposed, external timber. Repair as required.
	Inspect all exposed, external reinforced concrete for signs of spalling or cracking. Repair as required.
	Audit of damage to enclosed intumescent coatings. Repair as required.
Following fit-out or alterations	Audit of damage to intumescent coatings. Repair as required.
Following seismic shaking > SLS1 event	Inspections and repair as per b), c) and d) above

CERTIFICATE OF DESIGN WORK

MEMORANDUM FROM LICENSED BUILDING PRACTITIONER

Section 30C and Section 45, Building Act 2004

The Building	
Street address	APD Ltd
Suburb	Town/city Auckland
Postcode	Building consent no.
The Owner	
Name(s)	APD Ltd
Email	darien@apd.co.nz Phone 027 585 9088
Address	

Basis for providing this memorandum

I am providing this memorandum in my role as the **specialist** designer who carried out or supervised specific Primary structure elements of restricted building work (RBW) design work as described in this memorandum. Other designers will provide memoranda covering the remaining RBW design work. Refer also to the attached PS1.

Identification of restricted building work (RBW) design work

I, **Alyx Hodgson** carried out or supervised the following RBW design work:

Primary structure: B1

Design work that is RBW	Description (as required) and reference to plans and specifications	Carried out or supervised
Foundations and subfloor framing ✓	Waffle slab with in-slab tank As per calculations PS1 and calculations attached.	Supervised
Retaining walls ✕		
Beams ✕		
Portal ✕		
Bracing ✕		
Other (primary) ✕		

Note: SED = Elements subject to Specific Engineering Design outside of the scope of NZS3604:2011, unless otherwise noted.

Initial AH Date 08/08/2025

Waivers and modifications

Are waivers or modifications of the Building Code required?

No

If yes, please provide details of the waivers or modifications:

Building Code clause

Waiver/modification required

Issued by


Name	Alyx Hodgson	Design entity/company	DHC Consulting Group Ltd
Chartered status	CPEng	Chartered no.	1019377
Email	alyx@dhc.nz	Website	DHC.NZ
Phone (daytime)	0211120973	Phone (after hours)	0211120973
Mobile			
Postal address	PO BOX 9079, Newmarket, Auckland		
Physical address	26 Patey St Epsom		

Declaration

I, Alyx Hodgson, LBP state that I have applied the skills and care reasonably required of a competent design professional in carrying out or supervising the RBW described in this memorandum and that based on this, I certify that the RBW described in this memorandum:

- complies with the Building Code; or
- complies with the Building Code subject to any waiver or modification of the Building Code described in this memorandum.

Signature



Date 08/08/2025

Agreement to provide a producer statement during construction



Producer statement construction (PS3) or producer statement construction review (PS4)

I, being the owner / agent confirm that I have engaged the following producer statement author(s) **listed on the reverse side** of this document to be responsible for carrying out construction (PS3) or observing and supervising construction (PS4)

Name:

APD Ltd

☐ Owner ☐ Agent

Signature:

Date:

Building consent number (if known)

Address of project:

APD Ltd

Important notes:

In order to approve a building consent, Council must be satisfied on reasonable grounds that the provisions of the Building Code will be met. Council must also be satisfied that the building work is constructed in accordance with the building consent and Building Code before it can issue a code compliance certificate. Producer statements are a mechanism used for establishing compliance with the Building Code and are a cost-effective alternative to Council undertaking design reviews and inspections itself.

In some instances, building work that is specifically designed may require specialist installation / supervision. Where these elements are identified, the owner / agent may enter into an agreement with Council, to provide a producer statement to support compliance.

*This form serves as acknowledgement by the owner/agent that a producer statement will be provided on completion of the building work to which it relates. If at the time of application, the design professional or contractor details are unknown, please complete all other fields of this form noting the words **"to be advised"** in the author's name field.*

Producer statement construction (PS3) *If an owner / agent intends to provide a PS3 for internal waterproofing or installation of a heating appliance in lieu of an inspection the author must be on Councils Producer Statement Register and the author **must** phone the Call Centre on (09) 301 0101 to advise they will be performing the work. At this time Council staff will check and confirm the author is on the Register and if so, record the contractor's details against the building consent. An inspection is not required for this work. All other work performed by a contractor must be inspected and supported by a producer statement.*

Producer statement construction review (PS4) *Producer statements must be supported by way of site observation records and instructions, diary notes, testing and commissioning certificates, warranties, or such documents applicable to the construction, which has been undertaken / observed / supervised.*

On completion of the building work, Council will rely on the producer statement and supporting documentation when making its decision on whether to issue a code compliance certificate. All producer statement authors must be listed on the Auckland Council Producer Statement Register; the register can be found on the Councils website @ www.aucklandcouncil.govt.nz.

Please note that whilst every effort is made to identify producer statement requirements at consent stage; it may be possible that further information is required during construction and prior to the issue of the Code Compliance Certificate.

Tick if applies	Description of work (delete items not applicable)	Producer Statement Authors name (If unknown, write TBA)	Approved author #	Type
☐	Geotechnical - soil conditions, soil compaction, earthworks, excavations on boundary, etc			PS4
☒	Foundations, piling, masonry (Type A, B or C), compaction of hard-fill, drain bridging, raft slab	Alyx Hodgson	CPEng - 1019377	PS4
☐	Pile driving			PS3 PS4
☐	Internal waterproofing membranes			PS3
☐	External waterproofing membranes			PS3
☐	Heating appliance			PS3
☐	Stormwater management devices			PS4
☐	Waste water systems			PS4
☐	Swimming pool			PS4
☐	Precast and pre-stressed concrete			PS3 PS4
☒	Structural steel / portal frames			*
☐	Facade systems			PS4
☐	Installation, testing & commissioning certificates for fire safety systems			*
☐	Inspection & test plan (ITP) structural steel welding			*
☐	Fire safety systems			PS3
☐	Fire protection – interior surface finishes, floor coverings & suspended flexible fabrics			PS3
☐	Fire protection – intumescent coatings to structural steel			PS3
☐	Passive fire protection - stopping of fire rated walls, floors, ceilings & penetrations			PS3
☐	Heating ventilation & air-conditioning (HVAC)			PS4
☐	Proprietary product installation			PS3
☐	Racking			PS4
☐	Seismic performance			PS4
☐				
☐				

* Refer to conditions of consent for type of producer statement and certification requirements



Address APD Ltd

No.	Item of inspection	Timeframe
-----	--------------------	-----------

(Delete any that do not apply)

Notes:

- a) The above items of inspection are the minimum required to enable [DHC Consulting Group Ltd] to issue a PS4 – Producer Statement Construction Review for the specific engineering design items.
- b) The above items of inspection do not cover work constructed in accordance with NZS 3604:2011, for which inspections are to be undertaken by the Building Consent Authority.
- c) The Contractor/Builder is to provide [DHC Consulting Group Ltd] at least 24 hours' notice of the requirement for an inspection. The above timeframes are indicative, the Engineer and Contractor are to agree the timing of inspection prior to work commencing on site.
- d) A copy of this inspection schedule is to be held on site during the works, and the Contractor/Builder is to provide reasonable and safe access to enable works to be inspected according to the schedule.
- e) The above schedule does not necessarily represent the actual number of inspections to be undertaken. The number of inspections will depend on the construction method, sequence of the works and whether or not unforeseen conditions or difficulties are encountered on site.

Project:	IN SLAB 300D TANK DESIGN IN RESIDENTIAL WAFFLE SLABS	Project No:	7527-M(2)-220D
		Author:	Philip Seto
Subject:	Structural Calculations		

2. **FOUNDATIONS**

TYPICAL RESIDENTIAL WAFFLE SLAB WITH APD TANKS

Loadings:	Tib Width
Roof	3.0m
Floor	2.5m
STANDARD RESI.	Tib Width
Roof	3.0m
Floor	2.5m

Class M - 1 Storey - Ys = 40mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Add. Top bar</u>	<u>Rib Bar</u>
Weatherboard	85mm	300mm	SE62	Not Req.	HD12
Brick Veneer	85mm	300mm	SE72	Not Req.	HD12

Class M - 2 Storey - Ys = 40mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Addition. Top bar</u>	<u>Rib Bar</u>
Weatherboard	85mm	300mm	SE72	Not Req.	HD12
Brick Veneer	85mm	300mm	SE62	HD12 @ 1200crs	HD12

Class H - 1 Storey - Ys = 60mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Add. Top bar</u>	<u>Rib Bar</u>
Weatherboard	85mm	300mm	SE62	HD12 @ 1200crs	HD16
Brick Veneer	85mm	300mm	SE62	HD16 @ 1200CRS	HD12 (Maintain moisture to ground during constrution)

Class H - 2 Storey - Ys = 60mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Addition. Top bar</u>	<u>Rib Bar</u>
Weatherboard	85mm	300mm	SE62	HD12 @ 1200crs	HD12
Brick Veneer	85mm	300mm	SE72	HD16 @ 1200crs	HD12

SE72 mesh can be substituted with SE62 + HD12 Hockey Bars
SE62 + HD12 Hockey Bars > SE72 Mesh

TYPICAL RESIDENTIAL GARAGE WAFFLE SLAB WITH APD TANKS

Loadings: Tib Width
 Roof 3.0m
 Floor 2.5m
 Garge RESI.

Class M - 1 Storey - Ys = 40mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Add. Top bar</u>	<u>Rib Bar</u>
Weatherboard	105mm	300mm	SE82		HD12
Brick Veneer	105mm	300mm	SE82		HD12

Class M - 2 Storey - Ys = 40mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Addition. Top bar</u>	<u>Rib Bar</u>
Weatherboard	105mm	300mm	SE82	Not Req.	HD12
Brick Veneer	105mm	300mm	SE82	Not Req.	HD12

Class H - 1 Storey - Ys = 60mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Add. Top bar</u>	<u>Rib Bar</u>
Weatherboard	105mm	300mm	SE82	Not Req.	HD16
Brick Veneer	105mm	300mm	SE82	Not Req.	HD12 (Maintain moisture to ground during construction)

Class H - 2 Storey - Ys = 60mm

	<u>Slab</u>	<u>APD Pods</u>	<u>Mesh</u>	<u>Addition. Top bar</u>	<u>Rib Bar</u>
Weatherboard	105mm	300mm	SE82	Not Req.	HD12
Brick Veneer	105mm	300mm	SE82	HD16 @ 1200crs	HD12

SE72 mesh can be substituted with SE62 + HD12 Hockey Bars
 SE62 + HD12 Hockey Bars > SE72 Mesh

WAFFLE SLAB: CLASS M SOILS - TWO STOREY

WAFFLE SLAB DESIGN

EDGE LABEL: Two-storey - Class M



Project # :	7527
DESIGN BY :	PS
DATE :	

Slab details

Edge Beam Width = 300 mm	Total slab Depth = 305 mm	Stress block parameters:
Pod Depth = 220 mm	Rib width = 100 mm @ 1.2 m	α= 0.85
Top slab Depth = 85 mm	Concrete Strength = 25 MPa	β= 0.85

Design loads (calculated per 1m of foundation)

Load for centre heave/bearing (heaviest load case)					Load for Edge Heave (lightest load case)				
Element	Type	G	Q	LD (m)	Element	Type	G	Q	LD (m)
Slab	Edge Beam	7.32 kPa	1.50 kPa	0.3 m	Slab	Edge Beam	7.32 kPa	0.00 kPa	0.3 m
Slab	Waffle slab	2.48 kPa	1.50 kPa	0.33 m	Slab	Waffle slab	2.48 kPa	0.00 kPa	0.37 m
Roof	LIGHT ROOF	0.45 kPa	0.25 kPa	3.0 m	Roof	LIGHT ROOF	0.45 kPa	0.25 kPa	1.0 m
Wall	LIGHT CLAD	0.40 kPa	0.00 kPa	5.2 m	Wall	LIGHT CLAD	0.40 kPa	0.00 kPa	3.0 m
Floor	TIMBER FLOOR	0.60 kPa	1.50 kPa	2.5 m	Floor	TIMBER FLOOR	0.60 kPa	1.50 kPa	0.0 m
Additional load		0.0 kN/m	12.0 kN/m	-	Additional load		0.0 kN/m	0.0 kN/m	-
Load case		Load factors							
		G	Q	Scale					
LC1	Centre heave	1.0	0.5	1.1					
LC2	ULS bearing pressure	1.2	1.5	1.0					
LC3	Edge heave	0.9	0.0	1.0	4.3 kN/m				

Soil parameter	Design parameters for stiffened raft - Walsh Method
Ultimate bearing capacity : 300.0 kPa Φ _{bc} (CENTRE HEAVE)= 0.33 geotechnical reduction factor Φ _{bc} (ULS)= 0.50 ULS geotechnical reduction factor Soil Ultimate Pressure (LC1): 61.7 kPa OK Soil Ultimate Pressure (LC2): 119.05 kPa OK Soil class to AS2870 M 20< Ys <40 Ys= 40 mm Design Soil Movement Hs= 1.5 m Depth of design suction change 300 year Drought return period	Ym= 28 mm Centre Heave Differential Mound Movement e= 0.97 m Edge Distance (centre heave) 20% Edge heave movement reduction for wet soil profile Ym= 16 mm Edge Heave Differential Mound Movement e= 1.24 m Edge Distance (edge heave) Keep soil profile wet during construction k= 1000 kPa Mound Stiffeness Wf= 0.67 Assume Normal Profile Of Soil

Moment check (Centre Heave)	Moment check (Edge Heave)
W _{ULS} = 18.51 kN/m Edge ULS Load M*= 17.9 kNm/m Slab Bending Moment Mesh SE62 Slab mesh 33 mm Mesh top cover Amesh= 146 mm²/m f _{ym} = 500 MPa Reo Yeild Strength Additional Reinforcement , try: HD16 @ 1200crs A _{bar} = 168 mm²/m Hockey bars area f _{yb} = 500 MPa a= 73.8 mm Compression block depth d= 258 mm Effective depth ΦMn= 29.5 kNm/m Slab Moment Capacity OK	W _{st} = 4.28 kN/m Design load (stabilising) F _{EH1} = 6.5 kN Uplift force from edge heave acting at 1.04 m from e F _{EH2} = 6.6 kN Uplift force from edge heave acting at 0.55 m from e M*= 5.2 kNm/m Slab Bending Moment HD12 @ 1200crs Rib Bottom reinforcement 50 mm Bottom cover Abar= 94 mm²/m Reinforcement area fyb= 500 MPa Bar Steel Yeild Strengt a= 22.2 mm Compression block depth d= 249 mm Effective depth ΦMn= 9.5 kNm/m Slab Moment Capacity OK

Shear check (Centre Heave)	Balance strain check (Centre Heave)
W _{ULS} = 18.51 kN/m Edge ULS Load A _{cv} = 25800 mm² Effective shear area 19.0 mm Maximum conc. aggregate size k _a = 1.00 Aggregate size factor p _w = 0.0122 k _d = 1.00 Member depth factor v _c = 0.958 MPa Shear resisted by concrete ΦV _c = 18.5 kN Design shear strength provided by concrete OK Shear reinforcement is not required	e _c = 0.003 Max concrete compression strain e _y = 0.0025 Steel yield strain c _d = 141 mm Position of natural axis 0.75r _b = 1.5% Max. reinforcement ratio r _{min} = 0.3% Min. reinforcement ratio r _b = 1.5% Design reinforcement ratio OK

OUTPUT - Steel requirements

Mesh : Mesh SE62 Hockey bars: HD16 @ 1200crs Rib bottom Steel: HD12 @ 1200crs Shear Steel:

WAFFLE SLAB DESIGN

EDGE LABEL: Two-storey - Class M



Project # :	7527
DESIGN BY :	PS
DATE :	27/06/2023

Slab details										
Edge Beam Width = 300 mm			Total slab Depth = 305 mm			Stress block parameters:				
Pod Depth = 220 mm			Rib width = 100 mm @ 1.2 m			α= 0.85				
Top slab Depth = 85 mm			Concrete Strength = 25 MPa			β= 0.85				
Design loads (calculated per 1m of foundation)										
Load for centre heave/bearing (heaviest load case)						Load for Edge Heave (lightest load case)				
Element	Type	G	Q	LD (m)		Element	Type	G	Q	LD (m)
Slab	Edge Beam	7.32 kPa	1.50 kPa	0.3 m		Slab	Edge Beam	7.32 kPa	0.00 kPa	0.3 m
Slab	Waffle slab	2.48 kPa	1.50 kPa	0.33 m		Slab	Waffle slab	2.48 kPa	0.00 kPa	0.37 m
Roof	LIGHT ROOF	0.45 kPa	0.25 kPa	3.0 m		Roof	LIGHT ROOF	0.45 kPa	0.25 kPa	1.0 m
Wall	BRICK CLAD (70)	1.65 kPa	0.00 kPa	5.3 m		Wall	BRICK CLAD (70)	1.65 kPa	0.00 kPa	3.0 m
Floor	TIMBER FLOOR	0.60 kPa	1.50 kPa	2.5 m		Floor	TIMBER FLOOR	0.60 kPa	1.50 kPa	1.0 m
Additional load		0.0 kN/m	10.5 kN/m	-		Additional load		0.0 kN/m	0.0 kN/m	-
Load case		Load factors				Design load				
		G	Q	Scale						
LC1	Centre heave	1.0	0.5	1.1						
LC2	ULS bearing pressure	1.2	1.5	1.0						
LC3	Edge heave	0.9	0.0	1.0	8.2 kN/m					
Soil parameter					Design parameters for stiffened raft - Walsh Method					
Ultimate bearing capacity : 300.0 kPa Φ _{bc} (CENTRE HEAVE)= 0.33 geotechnical reduction factor Φ _{bc} (ULS)= 0.50 ULS geotechnical reduction factor Soil Ultimate Pressure (LC1): 83.58 kPa OK Soil Ultimate Pressure (LC2): 138.21 kPa OK Soil class to AS2870 M 20< Ys <40 Ys= 40 mm Design Soil Movement Hs= 1.5 m Depth of design suction change 300 year Drought return period					Ym= 28 mm Centre Heave Differential Mound Movement e= 0.97 m Edge Distance (centre heave) 20% Edge heave movement reduction for wet soil profile Ym= 16 mm Edge Heave Differential Mound Movement e= 1.24 m Edge Distance (edge heave) Keep soil profile wet during construction k= 1000 kPa Mound Stiffness Wf= 0.67 Assume Normal Profile Of Soil					
Moment check (Centre Heave)					Moment check (Edge Heave)					
W _{ULS} = 25.08 kN/m Edge ULS Load M*= 24.2 kNm/m Slab Bending Moment Mesh SE72 Slab mesh 31 mm Mesh top cover A _{mesh} = 192 mm²/m f _{ym} = 500 MPa Reo Yeild Strength Additional Reinforcement Required, try: HD16 @ 1200crs A _{bar} = 168 mm²/m Hockey bars area f _{yb} = 500 MPa a= 84.6 mm Compression block depth d= 259 mm Effective depth ΦMn= 33.1 kNm/m Slab Moment Capacity OK OK					W _{st} = 8.2 kN/m Design load (stabilising) F _{EH1} = 6.5 kN Uplift force from edge heave acting at 1.04 m from e F _{EH2} = 6.6 kN Uplift force from edge heave acting at 0.55 m from e M*= 0.3 kNm/m Slab Bending Moment HD12 @ 1200crs Rib Bottom reinforcement 50 mm Bottom cover A _{bar} = 94 mm²/m Reinforcement area f _{yb} = 500 MPa Bar Steel Yeild Strengt a= 22.2 mm Compression block depth d= 249 mm Effective depth ΦMn= 9.5 kNm/m Slab Moment Capacity OK					
Shear check (Centre Heave)					Balance strain check (Centre Heave)					
W _{ULS} = 25.08 kN/m Edge ULS Load A _{cv} = 25900 mm² Effective shear area 19.0 mm Maximum conc. aggregate size k _a = 1.00 Aggregate size factor ρ _w = 0.0139 k _d = 1.00 Member depth factor v _c = 1.000 MPa Shear resisted by concrete ΦV _c = 19.4 kN Design shear strength provided by concrete Shear reinfo R6 Shear reinforcement min shear reo area to be 1 s= 120 mm Spacing of shear reinforcement TRENCHED 600 OK N _{leg} = 0 Number of legs f _{yt} = 300 MPa Shear reo yeild strength V _s = 0.0 kN Φ _s = 0.75 Shear strength reduction factor ΦVn= 19.43 kN Slab Shear Capacity !!!!					e _c = 0.003 Max concrete compression strain e _y = 0.0025 Steel yield strain c _d = 141 mm Position of natural axis 0.75r _b = 1.5% Max. reinforcement ratio r _{min} = 0.3% Min. reinforcement ratio r _b = 1.7% Design reinforcement ratio NG!!!!=> use deeper beam TENCHED 600 OK					
OUTPUT - Steel requirements										
Mesh : Mesh SE72 Hockey bars: HD16 @ 1200crs Rib bottom Steel: HD12 @ 1200crs Shear Steel: 0R6@120										

BEAM LABEL : 265 Shallow edge beam

7527

PS

10/12/2021

PAGE :

Simple

1.2

0.1

m

1.2

2.7

20

0.4

0.7

0.4

0.3

0.68

0.5

12

12

BEAM DESIGN																	
BEAM TYPE		CONCRETE	DEPTH (mm)		245	φb	0.85	REACTION	G (kN)	Q (kN)	W _{DOWN} (kN)	W _{UP} (kN)	S _U (kN)	R _U (kN)			
fc (MPa)		25	WIDTH (mm)		300	φs	0.75										
nTOP REO		2	HD12	TOP COVER		50	fy_top								500	MPa	
nBOT REO		3	HD12	BOT COVER		50	fy_bot								500	MPa	
STIRRUP		0	R6	SPACING		100	fyt								300	MPa	
Avt_min		B S/(16 fyt) sqr(fc) =		9.4mm2		>	Avt =								0mm2		NG
As_min		B d sqr(fc) / (4 fy) =		137.3mm2		<	As =								226.2mm2		OK
a_max =		0.75 β (εc/(εc + εy)) d		63.6mm		>	a	26.6mm		OK							
φMn =		φb As fy (d - a/2)					s_min =	250mm		OK							
φVn =		φs (Av fyt d/s + vb Ac)															
vb =		(0.07+10pl) sqr(fc)		0.08sqr(fc)≤vb≤0.2sqr(fc)													
	POSITIVE BENDING		NEGATIVE BENDING		SHEAR												
	M*+ (kNm)	φ k1 Mn	M*-(kNm)	φ k1 Mn	V* (kN)	φ k1 Vn											
1.35G	3.31	24.47	0.00	16.74	11.02	27.13	OK										
1.2G+1.5Q	4.17	24.47	0.00	16.74	13.89	27.13	OK										
G+ψ _C Q+W _{DN}	3.27	24.47	0.00	16.74	10.89	27.13	OK										
0.9G+W _{UP}	2.20	24.47	0.00	16.74	7.35	27.13	OK										
G+ψEQ+E	3.19	24.47	0.00	16.74	10.62	27.13	OK										
SUMMARY																	
245Dx300B_fc=25MPa_2HD12 TOP & 3HD12 BOT + 0LEGGED R6-100																	
MOISTURE CONTENT : 18% OR LESS (12 MONTHS OR LONGER DURATION OF LOAD)																	